

September 29, 1969

G.S.A.  
Region 3  
Chief, Design & Construction Div.  
7th & D Streets S.W.  
Washington, D.C.

STAT

STAT

Gentlemen:

STATINTL

The following have come to light since the award of subject contract:

1. The mechanical removal plan - for room I N 440 was not included in the bid set. There are four copies enclosed. Eight copies were delivered to [redacted] the site on Friday September 26, 1969. The work changed was authorized by [redacted]

STATINTL

2. The standard GSA specification reference called for a free standing mounting device for the temperature and humidity recorders. We have to waive the requirement as there is no room in the space designated. The units can be mounted on an existing column where other controllers are mounted.

3. Paragraph 26-06e.3 of the specification calls for 63% [redacted] filtration. This should have read [redacted] The 63% [redacted] filters will be satisfactory. The 63% [redacted] will not physically fit in the space allocated.

STAT

STAT

STATINTL

STAT

Very truly yours,

STATINTL

[redacted]

Declass Review by NIMA / DoD

Approved For Release 2002/08/28 : CIA-RDP78B04747A000200030070-0

STATINTL

Approved For Release 2002/08/28 : CIA-RDP78B04747A000200030070-0